

GLAST activities in France

- Collaboration status and Team organization
- C-cell CAL design & qualification
 - mechanical structure
 - light yield
 - diode characterization
 - gluing or not gluing
- ASIC development
- Software activities



French collaboration

Interagency agreement

CNES, CEA, and IN2P3 formal support
Nov. '99

⇒ interagency agreement is in preparation April '00

International agreement

international agreement (LOA) in preparation, May '00

commitment: deliver the CAL mech. structure, pre-electronics mechanical assembly, AFEE asic


≈22.6 M€ (A-D) + 10.2 M€ (E)

science commitments: software (instr+science), source catalogue, science data center mirror site

* organization chart



French organization chart





CAL mechanical structure

Engineering model 1

(nov '99)

- low level sine wave 5-2000 Hz @ 0.25g along 3 axes (beginning & end)
- random vib. 20-2000 Hz (std) along 3 axes
 - tightening system safe, same signature before & after random vib.
 - no degradation of the CsI surface
 - ν(CsI long. mode) ~ 400 Hz

ENGINEERING MODEL 2

(summer '00)

- 8 x 12 cells (glued), AO dimensions, CsI + dummies, optical walls
- pressure caps for optical silicon pads
 - ⇒ vibration tests

engineering model 3

(autumn '00 -- PDR)

> 8 x 12 cells (block), final dimensions, CsI, final optical walls and caps

= qualification tests



Vibration test

- · Check Xal tightening system: rubber bands at log edges
- Check if Xal surface not damaged inside the cell

Test set-up

- 1 Crismatec polished Xta1 30x23x370 mm³ with home made ~1mm chamfers
- 2 dummies with same density (aluminum and steel)
- 3 cells composite structure closed with aluminum caps and a 1 mm thick silicon spacer (0.4mm walls)
- 4 rubber cords \$\ph\$1mm
- Clearance between crystal and walls 0.2 to 0.4mm


Vibration test levels

Low level sine vibrations 3 axis: 5 to 2000Hz at 0.25g

Random vibrations 3 axis: 20Hz 0.026g2/Hz

20 to 50Hz +6dB/oct 50 - 800Hz 0.16g²/Hz 800 - 2000Hz -6dB/oct 2000Hz 0.026g²/Hz

Low level sine vibrations 3 axis: 5 to 2000Hz at 0.25g



Test bench at EMITECH

Test results


- Lower natural frequency measured 400Hz transverse to structure
- · No visible degradation of the crystal surface
- No evolution of the system after random vibrations


Xal optical properties not measured prior to test (optical test bench not yet ready) but still the best light yield of all logs at Ecole Polytechnique.


New test foreseen with final optical reflector



CAL mechanical structure









Light yield studies

test stations operational

- > with μ, sources, positioning accuracy of 1 cm (CEA), 1 mm (X)
- 3 Xals or cells, diodes, calibrated readout electronics
- controlled pressure tests for optical pads in near future
- MONICA: diffusivity/reflectivity measurements of lining

lightyield vs. lining in C-cell

final estimates

May '00

lightyield vs. vibrations

1 cell with CsI and opt. walls, vib. tests

June '00

lightyield reproducibility

> eng. model 2, with <10 CsI Xals, vib. tests

summer '00

optical joint


ongoing

- testing various silicon pads, lightyield vs. cap pressure, cap closure
- || gluing solutions




Light yield studies

Thick Tyvek +alu+ white ends





Monica





Asic development

MEETING CAL Electrical Architecture

- Feb. '00
- **⋄** specs ready \leq June '00 \Rightarrow architecture review in Aug. '00
 - optimization of energy bands
- Asic design review

Dec. '00


development schedule

- start in June '00
- too tight schedule: run #1 in Feb. '01, run #2 in Sept. '01
 - ⇒ 5 more months (submission dates, more testing)
- characterized chips and corrections for the « flight » run ready for CDR.
- BUT run #2 chips to be delivered for BTEM March 1st '02
 - \Rightarrow 3 or 4 months late for BTEM delivery



Software

- * simulation activities: optimization of CAL design
 - more realistic CAL description
 - energy deposition in diodes
 - noise
 - asymetry...
 - Xal to Xal energy gain dispersion for calibration studies
 - readout threshold 2-5 MeV






Software

ENERGY RECONSTRUCTION AIGORITHMS

- profile fitting ok,
- low energy, cracks, ...

lightyield optical simulations

- light propagation in CsI, air gap, optical walls, opt. joint
- > running



*NEAR TUTURE

TKR/CAL feedback

summer '00